


**Notes:**

1. Use Select Granular Backfill Only.
2. Provide As Much Separation As Permitted By Trench Width.
3. Trench Tape (Warning Tape) Shall Be Placed 24" Above Water Pipe And At Least 12" Above Gas Pipe.
4. Gas Main Construction By Easton Utilities In Accordance With Easton Utilities Gas Construction Standards.
5. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
6. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS  WATER MAIN JOINT TRENCHING
 9/1/09 EU MANAGER OF ENGINEERING DATE	SEP 1, 09	
ISSUED: <u>NOV. 20, 2000</u>		STANDARD NO. W-1.01